



#1

BHARAT HEAVY ELECTRICALS LIMITED BHOPAL

**PRE QUALIFICATION REQUIREMENT(PQR)
420KV OIP BUSHINGS WITH PORCELAIN INSULATOR**

Date: 04.11.2024

Sl. No.	Description	Vendor's remarks (Y/N)
1	<p>The vendor should be either manufacturer of OIP bushings as per BHEL Enquiry <u>OR</u> their authorized representative.</p> <p>Authorized representative to submit authorization letter from the manufacturer as a documentary proof.</p>	
2	<p><u>420KV OIP Bushing:</u> Supplier should be approved by POWERGRID for 400KV or higher voltage rating OIP Bushings as on bid opening date.</p> <p>Supplier to submit POWERGRID approval letter/drg/Type Test reports in support of the same.</p>	

Singiren..

Naik

Prepared by: Singiren.E.Kandulna
Manager (BCE)

Approved by: Kulamani Naik
SDGM (BCE)